

Technical Data Sheet

Fire Alarm Cables- Circuit Integrity- CIC

WEST PENN WIRE



2833 West Chestnut Street
Washington, PA 15301
Toll Free: (800) 245-4964
Fax: (724) 222-6420
www.westpenn-wpw.com

PART NUMBER:	5320UZ
DESCRIPTION:	18/2 Solid bare copper conductors, unshielded with an overall jacket.
NEC RATING:	FPLR-CIC, NEC Article 760
APPROVALS:	(UL) or (ETL)us Listed
APPLICATION:	Indoor for (Circuit Integrity, Fire Alarm Circuit Integrity, Survivability)

Construction Parameters:

Conductor	18 AWG Bare Copper
Stranding	Solid
Insulation Material	Ceramifiable Silicon Rubber (CSR)
Insulation Thickness	0.041" Nom.
Number of Conductors	2
Shield	None
Drain	None
Jacket Material	Flame Retardant Polyethylene
Jacket Thickness	0.045" Nom.
Overall Cable Diameter	0.36" Nom.
Approximate Cable Weight	50 Lbs/1M' Nom.
Flame Rating	UL 1666 Riser Flame Test, UL2196- 2 hr.Test in Conduit

Electrical & Environmental Properties:

Temperature Rating	-20deg C to 105deg C
Operating Voltage	300 V RMS
Max.Capacitance Between Conductors @ 1 KHz	15 pf/ft Nom.
DC Resistance per Conductor @ 20deg C	5.86 Ohms/1M' Nom.
Insulation Colors	Black, Red
Jacket Color	Red
RoHS Compliant	Yes

Mechanical Properties:

Max. Recommended Pull Tension	40 lbs.
Min. Bend Radius (Install)	3.6"

Specification Issue Date: 7/06

This document is the property of West Penn Wire.
The information contained herein is considered
Proprietary and not to be reproduced by any means
Without written consent of West Penn Wire

Standard Lengths are 1000ft.
The Jacket is sequentially footmarked.
The information presented here is, to the best of our
knowledge, is true and accurate. However, since
conditions of use are beyond our control, all
recommendations or suggestions are presented
without guarantee or responsibility on our part. We
disclaim all liability in connection with the use of
information contained herein or otherwise.